

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER Mr. & Mrs. Wm. Twedt ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1975 Prior Road Mtn. Bluebird Drive _____
Reno, Nevada Southwest Pines Subdivision _____
 2. LOCATION S.W. 1/4 N.E. 1/4 Sec. 10 T. 19 17 N/S R 19 E WASHOE County _____
 PERMIT NO. None Required 047-020-48 Parcel No. _____ Subdivision Name _____
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Well Full of Rocks and Debris				
Cleaned out Casing, Brushed Perforations and Airlifted Well				
Surrounding well log information shows:				
Decomposed Granite		0	305	305
Broken granite	*	305	340	35
D.G. & Broken Granite		340	360	20

8. WELL CONSTRUCTION
 Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	0	360

Perforations:
 Type perforation Milled Slot
 Size perforation 3/32 X 3"
 From 360 feet to 320 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started September 13, 1994
 Date completed September 17, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	---	2 Hrs.

9. WATER LEVEL
 Static water level 250' feet below land surface
 Artesian flow No G.P.M. ----- P.S.I.
 Water temperature _____ °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name FREDRICK PUMP & Well Drilling Contractor
 Address P.O. Box 335, Jackson, CA 95642 Contractor
2545 Westview Blvd., Sparks, NV 89434
 Nevada contractor's license number issued by the State Contractor's Board 036313
 Nevada driller's license number issued by the 1475 Division of Water Resources, the on-site driller.
 Signed 9/23/94 By driller performing actual drilling on site or contractor
 Date _____

'94 OCT 19 AM 11:23
 STATE ENGINEER'S OFFICE