

OFFICE USE ONLY
 Log No. 46140
 Permit No. _____
 Basin. 087
 NOTICE OF INTENT NO. 269766

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Paul Carbone ADDRESS AT WELL LOCATION 450 Highland Dr
 MAILING ADDRESS same Virginia City, Nev
 2. LOCATION NE 1/4 NE 1/4 Sec. 7 T. 17 N/S R. 21 E. Storey County
 PERMIT NO. 3-431-07 Parcel No. V.C. Highlands Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Yellow Brown Clay Stone</u>		<u>0</u>	<u>30</u>	<u>30</u>
<u>Blue shale</u>		<u>30</u>	<u>60</u>	<u>30</u>
<u>Black Rock</u>		<u>60</u>	<u>150</u>	<u>90</u>
<u>Fractured & saturated</u>	<u>*</u>	<u>140</u>	<u>150</u>	

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
9 7/8 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 150 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>150</u>

Perforations:
 Type perforation Factory Milled
 Size perforation 3/32
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From 130 feet to 150 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 150 feet

9. WATER LEVEL
 Static water level 110 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Clean

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Enloe Drilling Contractor
 Address P.O. Box 1345 Contractor
Dayton, Nev
 Nevada contractor's license number issued by the State Contractor's Board 4739A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1480
 Signed Lee A. Enloe
 By driller performing actual drilling on site or contractor
 Date Sept 23, 1994

Date started Sept 21, 1994
 Date completed Sept 22, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>1 hr</u>

'94 OCT 26 P 2:04
 STATE ENGINEERS OFFICE