WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No.
Permit No.
Basin 083 A03 087

NOTICE OF INTENT NO. 26773

1. OWNER Brian Underdahl
MAILING ADDRESS 14360 Sundance
Reno Nev.

ADDRESS AT WELL LOCATION
210 Vermillion

2. LOCATION NW ¼ NE ¼ Sec. 6 T. 17 N/S R. 21E E. Storey County
PERMIT NO. SW SW (Issued by Water Resources) | 3-442-10 (Parcel No.) | V.C. Highlands (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown Clay | | 0 | 250 | 250 |
| Blue Clay | | 250 | 265 | 15 |
| Brown Sticky Clay | | 265 | 280 | 15 |
| Med Hard Brown Rock | | 280 | 320 | 40 |
| Blue Claystone | | 320 | 375 | 55 |
| Hard Blue Rock | | 375 | 500 | 125 |
| Blue Claystone | | 500 | 628 | 128 |
| Blue Fract Rock | | 628 | 740 | 112 |
| First Water ½ GPM 740 | | | | |
| Blue Claystone | | 740 | 875 | 135 |
| Brown Fract Rock | — | 875 | 940 | 65 |

'94 OCT 26 P2:04
RECEIVED
STATE ENGINEERS OFFICE

Date started 8-15, 1994
Date completed 8-22, 1994

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 4 | NA | 4 HRS |

8. WELL CONSTRUCTION
Depth Drilled 940 Feet Depth Cased 940 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 5/8 Inches | 0 Feet | 60 Feet |
| 8 3/4 Inches | 60 Feet | 940 Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13 | .188 | +1 | 940 |

Perforations:
Type perforation Factory Milled
Size perforation 3/32
From 860 feet to 940 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 940 feet

9. WATER LEVEL
Static water level 740 feet below land surface
Artesian flow NA G.P.M. P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Enloe Drilling Co. (Contractor)
Address P.O. Box 1345 Dayton Nev. (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 4739A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 590

Signed [signature] (By driller performing actual drilling on site or contractor)

Date 8-23-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627