

OFFICE USE ONLY  
 Log No. 46143  
 Permit No. 8-103  
 Basin 8-103

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26052

1. OWNER Lester Peters ADDRESS AT WELL LOCATION Lot 41  
 MAILING ADDRESS 22550 Ferretti Rd  
Graveland, Ca  
 2. LOCATION SW 1/4 NE 1/4 Sec 8 T 17 N/S R 23 E Lyon County  
 PERMIT NO. \_\_\_\_\_ Parcel No. Iron Mt Estates Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Loose sand &amp; gravel</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Cemented Gravel &amp; Boulders</u>		<u>2</u>	<u>60</u>	<u>58</u>
<u>Cemented Course gravel Yellow clay Filler</u>		<u>60</u>	<u>200</u>	<u>140</u>
<u>Saturated gravel &amp; sand consolidated</u>		<u>200</u>	<u>225</u>	<u>25</u>

'94 OCT 26 P 2:04  
 STATE ENGINEERS OFF

8. WELL CONSTRUCTION  
 Depth Drilled 225 Feet Depth Cased 225 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 Inches To 225 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>.13</u>	<u>.188</u>	<u>+1</u>	<u>225</u>

Perforations:  
 Type perforation Factory Milled  
 Size perforation 3/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 205 feet to 225 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 225 feet

9. WATER LEVEL  
 Static water level 110 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Clear

Date started Sept 13, 1994  
 Date completed Sept 14, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>8</u>		<u>2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Enloe Drilling Contractor  
 Address P.O. Box 1345 Contractor  
Dayton, Nev 89403  
 Nevada contractor's license number issued by the State Contractor's Board 4739A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1480  
 Signed Lee A. Enloe  
 By driller performing actual drilling on site or contractor  
 Date Sept 16 1994