

OFFICE USE ONLY  
 Log No. 46145  
 Permit No. \_\_\_\_\_  
 Basin 6-083

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26975

1. OWNER Lee Parker ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2440 Grissley Same  
Virginia, City, Nev  
 2. LOCATION SW 1/4 NE 1/4 Sec. 29 T. 18 N/S R. 21 E. Storey County  
 PERMIT NO. 3-022-12 - VC Highlands  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Med Hard Black Rock</u>		<u>300</u>	<u>400</u>	<u>100</u>
<u>saturated</u>	<u>340</u>			
	<u>380</u>			

8. WELL CONSTRUCTION  
 Depth Drilled 400 Feet Depth Cased 400 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 1/4 Inches To 300 Feet  
1100 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5 9/16</u>		<u>.188</u>	<u>180</u>	<u>400</u>

Perforations:  
 Type perforation Factory Milled  
 Size perforation 3/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 340 feet to 360 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 380 feet to 400 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level Apx 120 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Clean

Date started Sept 16, 1994  
 Date completed Sept 19, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>7</u>		<u>1</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Enloe Drilling Contractor  
 Address P.O. Box 1345 Contractor  
Dayton, Nev  
 Nevada contractor's license number issued by the State Contractor's Board 4739A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1480  
 Signed Lee A. Enloe  
 By driller performing actual drilling on site or contractor  
 Date Sept 21, 1994