

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26000

1. OWNER Barry Wharton ADDRESS AT WELL LOCATION 26000
 MAILING ADDRESS Not Available
 2. LOCATION NE 1/4 NE 1/4 Sec. 34 T. 18 N/S R. 23 E. 2 Year County _____
 PERMIT NO. _____ Parcel No. 15-002-22 Subdivision Name 23 Section
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Fractured sand</u>		<u>1</u>	<u>5</u>	<u>5</u>
<u>Fractured sand</u>		<u>5</u>	<u>35</u>	<u>30</u>
<u>Loose sand</u>		<u>35</u>	<u>143</u>	<u>108</u>
<u>Loose clay</u>		<u>143</u>	<u>196</u>	<u>53</u>
<u>Compact sand - low</u>		<u>196</u>	<u>355</u>	<u>159</u>
<u>Compact clay</u>		<u>355</u>	<u>425</u>	<u>70</u>
<u>Gravel</u>		<u>425</u>	<u>500</u>	<u>75</u>

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 231 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>	<u>13</u>	<u>1.33</u>	<u>1</u>	<u>231</u>

Perforations:
 Type perforation Jonah Galt
 Size perforation 3 1/2 x 8 x 4 in. pump
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 9/27/94 19____
 Date completed 1/23/94 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>4 1/4</u>	<u>100</u>	

9. WATER LEVEL
 Static water level 1710 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Dean Drilling Inc Contractor
 Address PO 599 Contractor
SS. NV 894109
 Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1376
 Signed W. Daniel
 By driller performing actual drilling on site or contractor
 Date 9/27/94