WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46170
Permit No.
Basin 099

NOTICE OF INTENT NO. 22907

1. OWNER Jim & Joy Brooks
MAILING ADDRESS 16755 Red Rock Road
Reno, NV
ADDRESS AT WELL LOCATION 16755 Red Rock Road
Reno, NV

2. LOCATION NW ¼ SW ¼ Sec. 4 T. 22 N/S R. 18 E. Washoe County
PERMIT NO. N/A (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [XX] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG & Brown Clay		0	136	136
Decomposed Granite		136	290	54
Gray Clay & Fine DG		290	462	172
White Sandstone		462	477	15
Gray Clay		477	500	30
White Sandstone		500	510	10
Gray Clay		510	525	15

Date started 8-27-94, 19
Date completed 8-31-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [XX] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx.	20	520	5

8. WELL CONSTRUCTION
Depth Drilled 525 Feet Depth Cased 525 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8	Inches	0 Feet	525 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	-1	525

Perforations:
Type perforation Mill Slot
Size perforation 1/8 x 3"
From 445 feet to 485 feet
From 505 feet to 515 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50±
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 525 feet

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EMDLCO DRILLING CO. (Contractor)
Address P.O. BOX 8056 Reno, NV (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 32166-c23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller (By driller performing actual drilling on site or contractor)
Date OCT. 13, 1994

'94 OCT 14 A11:52 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627