

WHITE-DIVISION OF WATER RESOURCES
 CANARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 46184
 Permit No. 051
 Basin 1
 NOTICE OF INTENT NO. 19616

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER NEWMONT GOLD CO.
 MAILING ADDRESS P.O. BOX 669
CARLIN, NV 89822-0669
 ADDRESS AT WELL LOCATION NEWMONT GOLD MINE NEAR CARLIN

2. LOCATION SW 1/4 SW 1/4 Sec 29 T 35 N/S R 51 E EUREKA County
 PERMIT NO. M/O 797 N/A
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---------------------------|--------------|------|-----|------------|
| BROWN ROCK & CLAY | | 0 | 80 | 80 |
| BROWN & BLACK ROCK | | 80 | 140 | 60 |
| BROWN ROCK & CLAY | | 140 | 220 | 80 |
| BROWN & BLACK ROCK W/CLAY | | 220 | 360 | 140 |
| BROWN RED & BLACK ROCK | | 360 | 410 | 50 |
| BROWN CLAY | | 410 | 475 | 65 |
| BROWN RED & BLACK GRAVEL | | 475 | 520 | 45 |

8. WELL CONSTRUCTION
 Depth Drilled 520 Feet Depth Cased 520 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12-1/4 inches 0 Feet 25 Feet
6-1/2 inches 25 Feet 520 Feet
 _____ inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 7 | 28 | .375 | 0 | 25 |
| 1-1/4 | 2 | SCH40 | 0 | 500 |

Perforations:
 Type perforation SLOTTED
 Size perforation .125
 From 500 feet to 520 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 480 feet to 520 feet

9. WATER LEVEL
 Static water level 150 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature _____ °F Quality _____

Date started MAY 31, 1994
 Date completed JUNE 2, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name LANG EXPLORATORY DRILLING
 Contractor
 Address 2286 WEST 1500 SOUTH
 Contractor
SALT LAKE CITY, UT 84104
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1829
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date SEPTEMBER 29, 1994

94 OCT -5 P2:13
 RECEIVED
 STATE ENGINEERS OFFICE