

OFFICE USE ONLY
 Log No. 46181
 Permit No. _____
 Basin 061

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27169

1. OWNER BARRICK GOLDSTRIKE MINES, INC. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. BOX 29 _____
ELKO, NV 89803 _____
 2. LOCATION NE 1/4 SE 1/4 Sec. 20 T. 36 N. R. 50 E. _____
EUREKA County
 PERMIT NO. M/O 846 Issued by Water Resources Parcel No. W-4 TRACT OF LAND _____
 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---------------------------------|--------------|------|-----|-----------|
| Gravel | | 0 | 15 | 15 |
| Red Sandy Clay | | 15 | 40 | 25 |
| Grey Sandy Clay | | 40 | 45 | 5 |
| Red Sandy Clay | | 45 | 95 | 50 |
| Red Sandstone | X | 95 | 110 | 15 |
| Yellow-Brown Clay and Sandstone | | 110 | 120 | 10 |
| Bentonite Pellet Seal | | 81 | 93 | |
| Bentonite Slurry | | 10 | 81 | |

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
8 3/4 Inches 0 Feet 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>4 1/2</u> | | <u>Sch 80 pvc</u> | <u>+3</u> | <u>120</u> |

Perforations:
 Type perforation slots
 Size perforation .020
 From _____ feet to _____ feet
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 10' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 93 feet to 120 feet

9. WATER LEVEL
 Static water level 83 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name HACKWORTH DRILLING, INC. Contractor
 Address P.O. BOX 850 Contractor
ELKO, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 020582
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
 Signed John C. Davis
 By driller performing actual drilling on site or contractor
 Date 11-2-94

Date started 9-27, 1994
 Date completed 9-27, 1994

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|------------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>5.6</u> | | |