GEN-38

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46195
Permit No.
Basin 061

NOTICE OF INTENT NO. 25628

1. OWNER Newmont Gold Company
MAILING ADDRESS P.O. Box 669
Carlin, NV 89822-0669

ADDRESS AT WELL LOCATION
Newmont Gold Mine near Carlin, NV

2. LOCATION NE ¼ SE ¼ Sec. 31 T 36 (N)/S R 50 E Eureka County
PERMIT NO. M/O - 223 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black & Gray Rock		0	20	20
Tan Clay & Rock		20	45	25
Tan & Gray Rock with Clay		45	90	45
Gray & Brown Rock		90	105	15
Gray & Brown Rock with Clay		105	145	40
Gray Rock		145	160	15
Gray & Tan Rock with Clay		160	175	15
Gray Rock with Clay		175	250	75

'94 OCT -5 P2:13
STATE ENGINEER'S OFFICE

Date started May 28, 19 94.
Date completed May 28, 19 94.

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	20 Feet
6½ Inches		20 Feet	250 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7	28	.375	0	20
1¼	2	SCH 40	0	210

Perforations:
Type perforation Slotted
Size perforation .125
From 210 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 194 feet to 250 feet

9. WATER LEVEL
Static water level 36 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address 2286 W. 1500 S. (Contractor)
Salt Lake City, UT 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1717

Signed David Conley (By driller performing actual drilling on site or contractor)
Date Oct 11, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627