WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 46199
Permit No.
Basin 105

NOTICE OF INTENT NO. 26801

1. OWNER Jerry Blades Construction
MAILING ADDRESS 1608 East Valley Rd. Gardnerville NV. 89401
ADDRESS AT WELL LOCATION 1608 East Valley Rd. Gardnerville NV. 89401

2. LOCATION ~~NE~~ ~~SE~~ 1/4 ~~SW~~ ~~SW~~ 1/4 Sec. 26 T 13 ~~N~~ S R 20 E Douglas County
PERMIT NO. NE SW (Issued by Water Resources) 23-295-59 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Overburden | | 0 | 3 | 3 |
| Hard Pack Clay w/ gravels | | 3 | 25 | 22 |
| Coarse gravels | | 25 | 63 | 38 |
| Gravels and Sands w/small Clay Balls | | 63 | 94 | 31 |
| Solid Brown Gummy Clay | | 94 | 145 | 51 |
| Large Gravels | XXX | 145 | 180 | 35 |

Date started 9/24, 1994
Date completed 9/26, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 30+ | 45 | 4 1/2 HRS |

8. WELL CONSTRUCTION
Depth Drilled 180' Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 11 1/4 | 0 | 180' |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13.03 | .188 | 0 | 180' |
| | | | | |

Perforations:
Type perforation Mill Slot
Size perforation 5 X 3/32
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 102
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 102 feet to 180' feet

9. WATER LEVEL
Static water level 23' feet below land surface
Artesian flow G.P.M. 30+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Company (Contractor)
Address 5551 Hwy 50E #3 Carson City NV. 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 9/26/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627