WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46200
Permit No.
Basin 105

NOTICE OF INTENT NO. 27508

1. OWNER BIFF PLEMEL
MAILING ADDRESS MINDEN, NV
ADDRESS AT WELL LOCATION 1499 WILLOW CREEK GARDNERVILLE

2. LOCATION NW ¼ SW ¼ Sec. 35 T. 13 (N/S) R. 20 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 23-540-10 (Parcel No.) WILLOW CREEK (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	4	4
CEMENTED GRAVEL		4	18	14
SANDY CLAY W/GRAVEL		18	33	15
CLAY		33	42	9
SANDY CLAY W/GRAVEL		42	67	25
CLAY		67	74	7
SANDY CLAY		74	77	3
CEMENTED GRAVEL		77	85	8
SAND + GRAVEL		85	99	14
CEMENTED GRAVEL		99	139	40
CEMENTED SAND	✓	139	156	17
SANDY CLAY		156	160	4

Date started 8-24, 1994
Date completed 8-24, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	25+	—	2

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	160 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	0	160

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 x 3/32
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 26 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD. (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
Signed Patt J. Moore (By driller performing actual drilling on site or contractor)
Date 8-29-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627