

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26573

1. OWNER MR. NEAL SPROTT ADDRESS AT WELL LOCATION 1561 LINDSAY GARDNERVILLE
 MAILING ADDRESS P.O. BOX 2365 GARDNERVILLE, NV

2. LOCATION NE 1/4 SE 1/4 Sec. 27 T. 14 N. R. 20 E DOUGLAS County
 PERMIT NO. 21-140-82 HIGH POINTE Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	12	12
Sand w/ gravel & boulders		12	83	71
Sandy clay w/ some gravel		83	197	114
Cemented sand		197	218	21
Sandy clay w/ some coarse sand		218	260	42
Coarse sand w/ sandy clay	✓	260	278	18
Sandy clay		278	283	5
Coarse sand w/ sandy clay	✓	283	296	13
Sandy clay		296	300	4

8. WELL CONSTRUCTION

Depth Drilled 300 Feet Depth Cased 298 Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 7/8 Inches	0 Feet 50 Feet
9 7/8 Inches	52 Feet 300 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	17	1.250	0	280
6 7/8	13	1.188	280	300

Perforations:

Type perforation Factory slotted
 Size perforation 2 1/2" x 1/2" J.C.

From T.C. 260 feet to 280 feet
 From Factory 280 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 300 feet

9. WATER LEVEL

Static water level 150 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. FALLON, NV 89406 Contractor

Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date 8-26-94

Date started 8-22, 19____
 Date completed 8-25, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25</u>		<u>3</u>