

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27290

1. OWNER BRIAN & KAREN ELLISON ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2725 Margret Drive 2780 Townsite
Reno, NV 89506 Reno, NV 89511
 2. LOCATION SW 1/4 SE 1/4 Sec 2 T 17N N/S R 19 E Washoe County
 PERMIT NO. 045-690-04 Calahan Ranch Area off Mt Rose
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulders & gravel		0	16	16
Sandy clay w/some gravel streaks		16	36	20
Sandy clay w/ larger gravel streaks		36	45	9
Decomposed granite w/clay streaks		45	48	3
Soft zone, sandy clay		48	68	20
Brown rusty clay		68	88	20
Soft zone		88	89	1
Brown clay-(sandy)		89	93	4
Large boulders		93	111	18
Bed rock, (volcanic) gray - fratured	X	111	115	4
Gray volcanic rock Fractured	X	117	121	4
Gray volcanic Fracture @		123		
Fracture @		125		
Fracture @	X	130		
Gray brown volcanic rock @ Fracture @	X	137		
Fracture @		145		
Fracture @		149		
Highly broken & fract Gray bron volcanic rock	X	156	160	4
		160	165	5

8. WELL CONSTRUCTION
 Depth Drilled 165 Feet Depth Cased 166 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 100 Feet
9 7/8 Inches 100 Feet 165 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	166

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 110 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 165 feet

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow _____ G.P.M. 60+ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 22549 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed [Signature] by driller performing actual drilling on site or contractor
 Date September 9, 1994

Date started 8-31-94, 19____
 Date completed 9-7-94, 19____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>60+</u>		