REPORT NO. 94.77

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO 46217
PERMIT NO
BASIN 089

NOTICE OF INTENT NO. 27580

OWNER Terrance McConnell
MAILING ADDRESS c/o DG Hand Const. 710 N. Curry C.C., Nv

ADDRESS OF WELL 175 Cottontail
Carson City, Nv 89704

2. WELL LOCATION NW 1/4 NE 1/4 SEC. 31 T 17N R 20 E Wshoe COUNTY

PERMIT NO PARCEL NO 50-366-03 SUBDIVISION NAME

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] Rev.
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
D.G.		0	115	115
Hard, fractured, white granite		115	175	60
Hard, fractured, salt & pepper granite		175		
w/some blue & quartz chips		175	220	45

'94 SEP 27 A10:56
STATE ENGINEER'S OFFICE

Notes

Date Started 9/14/94 Date Completed 9/19/94

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Lift

GPM	DRAWDOWN	TIME (HRS)
18		2

8. WELL CONSTRUCTION

Depth Drilled 220 Depth Cased 220

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 55 Feet
8 1/2 Inches 55 Feet 220 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D.	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+1	220

PERFORATIONS:
Type Perforation factory Size Perforation 3/32 x 3
From 200 Feet to 220 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 55'
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout

GRAVEL PACKED: [X] Yes [ ] No
From 55 Feet to 220 Feet

9. WATER LEVEL
Static Water Level 140 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge

Name Aqua Drilling & Well Service, Inc
Address 625 Spice Islands Dr Ste L
Sparks, Nv 89431

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO ON SITE 1132

Signed
By driller performing actual drilling on site or contractor

Dated 9/21/94