WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46218
Permit No.
Basin 089

NOTICE OF INTENT NO. 26794

1. OWNER Larry Yenko
MAILING ADDRESS 106 Opalite Ct. Reno NV. 89501
ADDRESS AT WELL LOCATION 340 McCellian Carson City NV. 89706

2. LOCATION NE ¼ SW ¼ Sec. 32 T. 17 N/S R. 20 E. Washoe County
PERMIT NO. Issued by Water Resources
50-371-32 Parcel No.
New Washoe City Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Blow Sands | | 0 | 63 | 63 |
| Course DG Sands | | 63 | 145 | 82 |
| Hard Blue Granite | | 145 | 210 | 65 |
| Hard Granite | | 210 | 315 | 105 |
| Hard Broken Granite w Small Fractures | XXX | 315 | 360 | 45 |
| GPM 15-18 | | | | |
| Static 140' | | | | |

'94 SEP 29 AM 10:30
STATE ENGINEER'S OFFICE

Date started 9-15, 1994
Date completed 9-21, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 15-18 | 100' | 4 HRS |

8. WELL CONSTRUCTION
Depth Drilled 360' Feet Depth Cased 360' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 11 1/4 Inches | 0 Feet | 55 Feet |
| 9 7/8 Inches | 55 Feet | 360 Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13.03 | .188 | 0 | 360' |

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 320' feet to 360' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 360' feet

9. WATER LEVEL
Static water level 140' feet below land surface
Artesian flow G.P.M. 15-18 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A&H Pump CO. Contractor
Address 5551 Hwy 50 E #3 Contractor
Carson City NV 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack
By driller performing actual drilling on site or contractor
Date 9/22/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627