

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER William Lee Betts ADDRESS AT WELL LOCATION 1340 Greene Ave SS NV 89429
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 NE 1/4 Sec 1 T 17 N 24 E 5000 County _____
 PERMIT NO. 17-023-19 Parcel No. _____ Subdivision Name MOUNTAIN VIEW SUB
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand, Clay		0	12	12
Sand, Gravel		12	32	20
Clay, Shale		32	80	48
Clay, Sand		80	106	26
Clay (Gravel)	117	106	117	11
Coarse Gravel	139	117	139	22

'94 SEP 29 AM 1:49
 STATE ENGINEERS OFF.

8. WELL CONSTRUCTION
 Depth Drilled 139 Feet Depth Cased 110 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 139 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>13</u>	<u>1.88</u>	<u>11</u>	<u>139</u>

Perforations:
 Type perforation Tough Cut
 Size perforation 3/16 x 8" x 4 non-weld ports
 From 119 feet to 139 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 139 feet

9. WATER LEVEL
 Static water level 32 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 62 °F Quality P Good

Date started 9/9/94, 19____
 Date completed 9/11/94, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20-25</u>	<u>8pm</u>	<u>4 hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name George W. Hilling, Jr. Contractor
 Address 2200 S. 5th St. Contractor
22 NW 89429
 Nevada contractor's license number issued by the State Contractor's Board. 00231941
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 18716
 Signed George W. Hilling, Jr.
 By driller performing actual drilling on site or contractor
 Date 9/21/94