WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46221
Permit No.
Basin 099

NOTICE OF INTENT NO. 24980

1. OWNER Brausey, Mark & Annette
MAILING ADDRESS 14380 Cheriot, Reno, NV
ADDRESS AT WELL LOCATION 14380 Cheriot, Reno, NV

2. LOCATION SE ¼ NE ¼ Sec. 23 T. 23 N/S R. 18 E. washoe County
PERMIT NO. N/A (Issued by Water Resources) 078-092-09 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[XX] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG & BROWN CLAY		0	57	57
YELLOW CLAY		57	60	03
BROWN CLAY		60	68	08
DECOMPOSED GRANITE		68	74	06
BROWN CLAY		74	158	84
DECOMPOSED GRANITE		158	200	42

'94 OCT 14 AM 11:52
STATE ENGINEER'S OFFICE

Date started 8-23-94, 19
Date completed 8-24-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	50	190	3

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	Inches	From (Feet)	To (Feet)
	9 7/8	0	200

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14	.188	-1	200

Perforations:
Type perforation Mill Slot
Size perforation 1/8" x 3"
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [XX] Yes [ ] No
Depth of Seal 50+
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 60' feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EMDLCO DRILLING (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, NV 89507
Nevada contractor's license number issued by the State Contractor's Board 32166-C23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller (By driller performing actual drilling on site or contractor)
Date Oct. 13, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627