WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46223
Permit No.
Basin 085

NOTICE OF INTENT NO. 22906

1. OWNER Beni, Stan
MAILING ADDRESS 2605 Scholl Rd.
Reno, NV 89503

ADDRESS AT WELL LOCATION parcel "A" El Molino
Reno, Nv

2. LOCATION NE ¼ NW ¼ Sec. 30 T 21 (N)S R 21 E WASHOE County
PERMIT NO. N/A Issued by Water Resources | 076-380-25 Parcel No. | Spanish Springs Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY, SAND & GRAVEL		0	125	125
BROWN CLAY & DG		125	280	155
DG W/CLAY LAYERS		280	320	40
VOLCANIC GRAVEL		320	400	80

'94 OCT 14 A11:52
STATE ENGINEER

Date started 7-13-94, 19
Date completed 8-3-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	20	380	4

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12¼"	Inches	0	Feet	20	Feet
9 7/8	Inches	20	Feet	320	Feet
6 1/8	Inches	320	Feet	400	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14	.188	-1	320
5 9/16	13	.250	280	400

Perforations:
Type perforation Mill Slot
Size perforation 1/8" x 3"
From 160 feet to 300 feet
From 340 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured

Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 320 feet

9. WATER LEVEL
Static water level 136 feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EMDLCO DRILLING (Contractor)
Address P.O. 8056 (Contractor)
Reno, NV 89507

Nevada contractor's license number issued by the State Contractor's Board 32166-C23

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418

Signed Bruce Miller (By driller performing actual drilling on site or contractor)
Date OCT. 13 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627