PZ 93-15

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46224
Permit No.
Basin 061

NOTICE OF INTENT NO. 24292

1. OWNER BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO, NEVADA 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SE ¼ NE ¼ Sec. 30 T. 36 N/S R. 50 E. EUREKA County
PERMIT NO. WAIVER#M/0-441 (Issued by Water Resources) | Parcel No. N/A | Subdivision Name N/A

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
PUMPED 16 LB/GAL CEMENT FROM 800 FT. TO SURFACE				
IN FIRST COMPLETION AND FROM 160' TO SURFACE				
IN SECOND COMPLETION				

Date started SEPT 14, 1994
Date completed SEPT 14, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 800 Feet Depth Cased 760 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 Inches	0 Feet	20 Feet	
6-1/2 Inches	20 Feet	800 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7	28	.375	0	20
1-1/2	2	SCH40	0	760
1-1/2	2	SCH40	0	120

Perforations:
Type perforation SLOTTED
Size perforation 1/8"
From 760 feet to 800 feet
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No HOLE PLUG IN BETWEEN GRAVELED AREAS
From 105-170 feet to 750-800 feet

9. WATER LEVEL
Static water level 270 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature COOL °F Quality CLEAR/GRAY

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UT 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller T-1716-1

Signed Kevin Ellison
(By driller performing actual drilling on site or contractor)

Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627