

OFFICE USE ONLY
 Log No. 46238
 Permit No. 105
 Basin. 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26796

1. OWNER Bob Starke Dairy ADDRESS AT WELL LOCATION 876 Centerville Ln Gardnerville NV 89401
 MAILING ADDRESS 876 Centerville Ln Gardnerville NV 89401
 2. LOCATION SW 1/4 SE 1/4 Sec 7 T 12 S R 20 E Douglas County
 PERMIT NO. 19-240-03 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Overburden</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Gray Silty Sand/Clay</u>		<u>3</u>	<u>8</u>	<u>5</u>
<u>Course Peat Gravels</u>		<u>8</u>	<u>45</u>	<u>37</u>
<u>Gray Silty Clay</u>		<u>45</u>	<u>68</u>	<u>23</u>
<u>Course Sand w/small Gravels</u>		<u>68</u>	<u>79</u>	<u>11</u>
<u>Large River Gravels XXX</u>		<u>79</u>	<u>140</u>	<u>61</u>

79 OCT 13 P 1:08
 STATE ENGINEERS OF NV

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>12 1/4</u>	<u>0</u>	<u>140</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.34</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/32
 From 120 feet to 140 feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 100' Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 100' feet to 140' feet

9. WATER LEVEL
 Static water level 2' feet below land surface
 Artesian flow 35+ G.P.M. P.S.I.
 Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H Pump Co. Contractor
 Address 5551 Hwy 50 E#3 Carson City NV 89701 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael Beck
 By driller performing actual drilling on site or contractor
 Date 9/31/94

Date started 9/25, 1994
 Date completed 9/28, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>35+</u>	<u>30</u>	<u>4 HRS</u>