

OFFICE USE ONLY  
 Log No. 46240  
 Permit No. \_\_\_\_\_  
 Basin. 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26580

1. OWNER ACE ANDERSON ADDRESS AT WELL LOCATION 941 MEADOWVIEW GARDNERVILLE, NV  
 MAILING ADDRESS P.O. BOX 10198 ZEPHYR COVE, NV

2. LOCATION NW 1/4 NE 1/4 Sec. 15 T 12 @ N S R 20 E DOUGLAS County  
 PERMIT NO. 27-742-05 GARDNERVILLE RANCHOS Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy clay w/ some gravel</u>		<u>110</u>	<u>121</u>	<u>11</u>
<u>Gravel w/ short clay strks.</u>		<u>121</u>	<u>174</u>	<u>53</u>
<u>Sandy clay w/ some gravel</u>		<u>174</u>	<u>181</u>	<u>7</u>
<u>Gravel w/ short clay strks.</u>		<u>181</u>	<u>234</u>	<u>53</u>
<u>Sandy clay w/ some gravel</u>		<u>234</u>	<u>240</u>	<u>6</u>

8. WELL CONSTRUCTION  
 Depth Drilled 110 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)  
 From 7 7/8 Inches 110 Feet 240 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13</u>	<u>1.58</u>	<u>100</u>	<u>240</u>

Perforations:  
 Type perforation Factory slotted / T.C.  
 Size perforation 3 x 3/32  
 From Factory 220 feet to 240 feet  
 From T.C. 200 feet to 220 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 112 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD. FALLON, NV 89406 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535  
 Signed Jerald W. Phinney By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_

Date started 9-13, 1994  
 Date completed 9-15, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25+</u>		<u>7</u>

'94 OCT 12 P 1:08  
 RECEIVED  
 STATE ENGINEERS OFFICE