

OFFICE USE ONLY  
 Log No. 46241  
 Permit No. \_\_\_\_\_  
 Basin. 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27513

1. OWNER KASIMIR PAWLISZYN ADDRESS AT WELL LOCATION 961 RIVERVIEW  
 MAILING ADDRESS 961 RIVERVIEW DR GARDNERVILLE

2. LOCATION SW 1/4 NE 1/4 Sec. 15 T. 12 N. R. 20 E. DOUGLAS County  
 PERMIT NO. 27-742-02 GARDNERVILLE RANCHOS Subdivision Name  
 Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay w/ cobbles		0	5	5
cobbles, gravel w/ sandy clay		5	80	75
sandy clay w/ gravel		80	89	9
cobbles, gravel w/ short sandy clay streaks		89	140	51
sandy clay w/ gravels		140	163	23
gravel w/ short sandy clay streaks		163	198	35
sandy clay w/ gravel		198	210	12
gravel w/ short sandy clay streaks		210	257	47
sandy clay w/ same gravel		257	260	3

8. WELL CONSTRUCTION  
 Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 5/8</u> Inches	<u>0</u>	<u>50</u> Feet
<u>9 7/8</u> Inches	<u>50</u>	<u>260</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>260</u>

Perforations:  
 Type perforation Factory Slotted / T.C.  
 Size perforation 3/4" x 3/32"  
 From Factory 240 feet to 260 feet  
 From T.C. 220 feet to 240 feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 260 feet

9. WATER LEVEL  
 Static water level 107 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD. Contractor  
FALLON, NV 89406  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535  
 Signed Jerald W. Plim  
 By driller performing actual drilling on site or contractor  
 Date 9-27-94

Date started 9-19, 1994  
 Date completed 9-27, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25+</u>		<u>3</u>

94 OCT 12 P1:08  
 RECEIVED OFFICE  
 STATE ENGINEERS OFFICE