

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26577
 ADDRESS AT WELL LOCATION 855 MARLION WAY, GARDNERVILLE

1. OWNER BRIAN MCCA
 MAILING ADDRESS GARDNERVILLE

2. LOCATION NW 1/4 SW 1/4 Sec. 17 T. 12 N. R. 20 E. DOUGLAS County
 PERMIT NO. 27-672-05 Parcel No. _____ Subdivision Name CHAMBERS FIELD

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	1	1
Sandy clay w/ cobbles		1	5	4
cobbles gravel		5	39	34
Sandy clay w/ gravel		39	44	5
Cobbles gravel		44	78	34
Sandy clay w/ gravel		78	84	6
gravel w/ short clay strks	✓	84	124	40
Sandy clay		124	128	4
gravel w/ short clay strks	✓	128	140	12

94 OCT 12 P 1:08
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 100 Feet
9 7/8 Inches 100 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1.88</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory Slotted
 Size perforation 3 x 3/32
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 140 feet

9. WATER LEVEL
 Static water level 28 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. FALLON, NV 89406 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed James W. Rhinell By driller performing actual drilling on site or contractor
 Date 9-8-94

Date started 9-6, 1994
 Date completed 9-8, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Air</u>	<u>257</u>		<u>1</u>