

OFFICE USE ONLY  
 Log No. 46245  
 Permit No. \_\_\_\_\_  
 Basin. 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27516

1. OWNER GARY SCHWOB-NELSON ADDRESS AT WELL LOCATION 1380 CALLE PEQUEÑO  
FISH SPRINGS, NV  
 MAILING ADDRESS 1380 CALLE PEQUEÑO  
FISH SPRINGS, NV

2. LOCATION NE 1/4 NE 1/4 Sec. 5 T. 12 N. R. 21 E DOUGLAS County  
FISH SPRINGS  
 PERMIT NO. 35-130-15 Parcel No. \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other M.U.D.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/GRAVEL		0	4	4
COBBLES		4	8	4
SANDY CLAY		8	15	7
CEMENTED GRAVEL		15	29	14
SANDY CLAY w/GRAVEL		29	36	7
CEMENTED GRAVEL		36	42	6
SANDY CLAY w/GRAVEL		42	54	12
CEMENTED GRAVEL		54	61	7
SANDY CLAY w/GRAVEL		61	88	27
CEMENTED GRAVEL		88	92	4
SANDY CLAY w/GRAVEL		92	124	32
CLAY		124	144	20
CEMENTED GRAVEL		144	148	4
CLAY		148	181	33
COARSE SAND + GRAVEL		181	186	5
COARSE SAND		186	190	4
COARSE SAND + GRAVEL		190	197	7
SANDY CLAY w/GRAVEL		197	200	3

194 OCT 12 P 1:08  
 RECEIVED BY STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>200</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 X 3/32  
 From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 100 feet to 200 feet

9. WATER LEVEL  
 Static water level 30 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC  
 Contractor  
 Address 7780 CURRY RD.  
 Contractor  
FALLON, NV 89406  
 Nevada contractor's license number 27673  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1726  
 Division of Water Resources, the on-site driller  
 Signed Pat J. Mooney  
 By driller performing actual drilling on site or contractor  
 Date 9-15-94

Date started 9-12, 1994  
 Date completed 9-15, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR LIFT</u>	<u>25+</u>	<u>-</u>	<u>1</u>

TEST METHOD:  Bailer  Pump  Air Lift