WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46266
Permit No.
Basin 8-103

NOTICE OF INTENT NO. 75974

1. OWNER Lenore Seville
MAILING ADDRESS 223 Prospector Rd
Dayton Nv
ADDRESS AT WELL LOCATION Same

2. LOCATION SW ¼ NE ¼ Sec. 30 T 17N N/S R 22 E Storey County
PERMIT NO. N/A (Issued by Water Resources) 3-271-11 (Parcel No.) Marktwain (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil Boulders		0	60	60
Tan Clay		60	105	45
Gravel with Some Clay		105	156	51
		156	182	26
Tan clay		182	199	17
Gravels with Some Boulders		199	225	26
Brown Clay		225	262	32
Gravels with Some Coarse	✓	262	276	14

Date started Sep 22 1994
Date completed Sep 23 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed For 3 Hours And produced about 30 Gallons A Min		
Approx 30 GPM		

8. WELL CONSTRUCTION
Depth Drilled 276 Feet Depth Cased 276 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches	Feet	0	60 Feet
8 3/4 Inches	Feet	60	276 Feet
Inches	Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	15.00	3/16	+1	276

Perforations:
Type perforation AIR PERF
Size perforation 1/4 x 3 Long 6 Rows
From 200 feet to 276 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 276 feet

9. WATER LEVEL
Static water level 200 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality V Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Flash Drilling Inc (Contractor)
Address Po Box 579 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0042
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1827
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Sep 22 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627