WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46269
Permit No.
Basin 83103

NOTICE OF INTENT NO. 25997

1. OWNER Gene Saccone
MAILING ADDRESS SAME
ADDRESS AT WELL LOCATION 6070 Shetland Silver Springs, NV. 89429

2. LOCATION SE ¼ NW ¼ Sec. 11 T. 17 N/S R 23 E Lyon County
PERMIT NO. N/A (Issued by Water Resources) 19-371-40 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
Tan Clay		4	46	42
Fine Sand		46	69	33
Fine Gravel		69	121	52
Tan Clay		121	142	21
Fine Gravel	✓	142	157	15

'94 OCT 18 P4:33
RECEIVED
STATE ENGINEERS OFFICE

Date started 9-21, 1994
Date completed 9-22, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed For 3 Hours And Produced about 15 Gallons A Min		

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 157 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 160 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	+1	157

Perforations:
Type perforation Air Perf
Size perforation 1/4 x 5 Rows x 20 Feet long
From 140 feet to 157 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 157 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leech Drilling Inc (Contractor)
Address PO Box 599 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature] By driller performing actual drilling on site or contractor
Date 10-14-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627