WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46269
Permit No.
Basin 8-103

NOTICE OF INTENT NO. 26000

1. OWNER Gene Saccone
MAILING ADDRESS SAME
ADDRESS AT WELL LOCATION 6110 Shetland Drive Silver Springs, NV. 89429

2. LOCATION SE ¼ NW ¼ Sec. 11 T. 17 N/S R. 23 E. Lyon County
PERMIT NO. N/A (Issued by Water Resources) Parcel No. 19-371-39 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Fine Gravel		3	35	32
Course Gravel		35	66	31
Boulders		66	96	30
Course Gravel		96	104	8
Course Gravel with Some Sand	✓	104	158	54

STATE ENGINEER'S OFFICE RECEIVED OCT 18 '94 P 4:33

Date started 9-26, 1994
Date completed 9-27, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed for 2 Hours And Produced about 30 Gallons A min		

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 158 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	71	158

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	15.00	3/16	71	158

Perforations:
Type perforation Torch Cut
Size perforation 1/4 x 4" long x 6 Rows
From 140 feet to 158 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 158 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Peck Drilling Inc (Contractor)
Address PO Box 579 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1527
Signed (By driller performing actual drilling on site or contractor)
Date 10-14-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627