Washoe Co. Health Permit #5182

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46270
Permit No.
Basin 6-087

NOTICE OF INTENT NO. 21598

1. OWNER Ron Palmer
MAILING ADDRESS 9675 Timothy
Reno, NV 89511

ADDRESS AT WELL LOCATION
3105 Holcomb Lane
Reno, NV 89511

2. LOCATION NE ¼ NW ¼ Sec. 12 T 18N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 40-650-18 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil-Black dirt		0	4	4
Brown clay with multi				
colored rocks		4	60	56
No clay, sands w/multi				
colored rocks-gravels	x	60	90	30
Larger gravels w/sand	x	90	156	66

Date started ~~XXX~~ 9-28, 19 94
Date completed 9-28, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
38	16'	2 hours

8. WELL CONSTRUCTION
Depth Drilled 156 Feet Depth Cased 156 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8 Inches	0 Feet	156 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	156

Perforations:
Type perforation Factory
Size perforation .070 tripple row
From 116 feet to 156 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 106
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 106 feet to 156 feet

9. WATER LEVEL
Static water level 53 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MacKay Pump & Geothermal, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on site or contractor)
Date 10-9-'94

OCT 12 P1:09 '94 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627