

WHITE-DIVISION OF WATER RESOURCES
 CANARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 46275
 Permit No. _____
 Basin 6-087

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21579

1. OWNER Jodie Colapietro ADDRESS AT WELL LOCATION same
 MAILING ADDRESS 15870 Toll Rd.
Reno, NV 89511

2. LOCATION NW 1/4 SE 1/4 Sec. 34 T. 18N N/S R 20 E Washoe County
 PERMIT NO. 17-211-23 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soils w/clays, small rocks-		0	35	35
Small rocks w/yelow clay		35	55	20
Brn Clay/Red-Blk shale		55	90	35
Green & multi colored rocks		90	120	30
Blue shales w/some blue clays-occasional volcanics		120	150	30
Picked up water at 150 xx				
Green/Blue rock with shales & volcanics	xx	150	190	40
Grey shales-blue rock	xx	190	219	29

8. WELL CONSTRUCTION
 Depth Drilled 219 Feet Depth Cased 219 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 219 Feet
9 7/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	219

Perforations:
 Type perforation Factory
 Size perforation .070 tripple perf
 From 199 feet to 219 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 56 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 56 feet to 219 feet

Date started 9-14, 19 94
 Date completed 9-15, 19 94

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2 hrs

9. WATER LEVEL
 Static water level 89 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MacKay Pump & Geothermal, Inc. Contractor
 Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Brown MacKay
 By driller performing actual drilling on site or contractor
 Date 9-16-'94