

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27032

1. OWNER Kapas Konstruktion ADDRESS AT WELL LOCATION 5975 Solias  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 SW 1/4 Sec. 22 T 18 N/S R. 28 E Churchill County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material          | Water Strata | From | To  | Thickness |
|-------------------|--------------|------|-----|-----------|
| Brown Sand        | ✓            | 0    | 20  | 20        |
| Brown Clay        |              | 20   | 21  | 1         |
| Brown Sand        | ✓            | 21   | 30  | 9         |
| Grey Sand         | ✓            | 30   | 47  | 17        |
| Black Sand & Clay |              | 47   | 47  | 20        |
| Green Sand        | ✓            | 47   | 75  | 8         |
| Grey Clay         |              | 75   | 89  | 14        |
| Grey Black Sand   | ✓            | 89   | 107 | 18        |
| Brown Clay        |              | 107  | 110 | 3         |
| Brown Silt        | ✓            | 110  | 112 | 2         |
| Dark Gravel       | ✓            | 112  | 128 | 15        |
| Black Sand        | ✓            | 127  | 150 | 23        |

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 127 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
6 Inches 50 Feet 127 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6.75</u>        | <u>.129</u>         | <u>.188</u>             | <u>+1</u>   | <u>127</u> |

Perforations:  
 Type perforation machine slot / Holt knife  
 Size perforation .050  
 From 25 feet to 28 feet  
 From 120 feet to 125 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 25  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 7 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality untested

Date started July 23, 1994  
 Date completed July 23, 1994

7. WELL TEST DATA

| TEST METHOD:   | G.P.M.    | Draw Down (Feet Below Static) | Time (Hours) |
|--|-----------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>15</u> |                               | <u>1</u>     |

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Welsco Contractor  
 Address Box 888 Fallon Nev Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 11752  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772-T  
 Signed Jesús Manuquena  
 By driller performing actual drilling on site or contractor  
 Date SEP 19 1994