

OFFICE USE ONLY  
 Log No. 46290  
 Permit No. \_\_\_\_\_  
 Basin 0923

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27301

1. OWNER JOHN ZIMMERMAN ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 7680 Jays Place Same  
Reno, Nevada 89506  
 2. LOCATION SE 1/4 SE 1/4 Sec 3 T 20N N/S R 19 E Washoe County  
 PERMIT NO. 088-081-18 Golden Valley  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING:				
Total depth 252 feet Est. 1 GPM with air.				
Decomposed granite with rock		252	256	4
Granite rock, med hard		256	266	10
Granite rock, med soft		266	283	17
Granite rock, soft zone		283	290	7
Granite rock, med hard		290	296	6
Granite rock, soft zone	X	296	301	5
Broken fractured granite	X	301	320	19
Broken fractured weathered granite	X	320	334	14
Granite rock with weathered streaks	X	334	360	26

8. WELL CONSTRUCTION  
 Depth Drilled 360 Feet Depth Cased 360 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 Inches To 360 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	360

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 300 feet to 360 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal deepening  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 256 feet to 360 feet

9. WATER LEVEL  
 Static water level 233.5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 10 P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date September 26, 1994

Date started 94 OCT -4 P 11:19 9-19-94, 19\_\_\_\_\_  
 Date completed STATE ENGINEERS OFFICE 9-20-94, 19\_\_\_\_\_  
 7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		