WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46292
Permit No.
Basin 092B

NOTICE OF INTENT NO. 27302

1. OWNER JAMES KRUEGER
MAILING ADDRESS 3475 Warpaint
Reno, Nevada 89506

ADDRESS AT WELL LOCATION
Same

2. LOCATION NW ¼ SE ¼ Sec. 11 T. 20N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 088-171-12 (Parcel No.) Golden Valley (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Static water level in well @ 147 feet.				
Estimate 1 GPM.				
Total depth of well @156 feet.				
WELL DEEPENING:				
Decomposed granite		156	210	44
Soft zone DG (app 5 GPM)	X	210	215	5
Decomposed granite		215	226	11
Soft zone, DG weathered brown	X	226	231	5
Decomposed granite		231	250	19
Soft zone, Decomposed granite brown	X	250	256	6
Decomposed grnite		256	272	16
Soft zone, DG weathered brown	X	272	275	3
Decomposed granite weathered gray, soft streaks	X	275	312	37
Pinkish gray, DG very soft		312	320	8
Gray Decomposed Granite very soft		320	330	

Date started 9-22-94, 19
Date completed 9-23-94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
17		

8. WELL CONSTRUCTION
Depth Drilled 330 Feet Depth Cased 330 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	156 Feet	330 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		188	0	330

Perforations:
Type perforation factory ~~XXXX~~ sawed slot
Size perforation 3/32 x 3 x 5 around
From 225 feet to 285 feet
From 305 feet to 325 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal deepening
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 156 feet to 330 feet

9. WATER LEVEL
Static water level 147 feet below land surface
Artesian flow G.P.M. 17 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908

Signed (By driller performing actual drilling on site or contractor)
Date September 27, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627