

OFFICE USE ONLY
 Log No. 46284
 Permit No. _____
 Basin. 083

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25286

1. OWNER Steven S. Goodall ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Post Office Box 10816 Patrick, Nevada
Reno, Nevada 89520
 2. LOCATION NE 1/4 NE 1/4 Sec. 31 T. 20 N/S R. 22 E Washoe County
 PERMIT NO. 54393 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay sand, cobbles		0	16	16
Volcanic Rock		16	69	53
Sandy clay		69	77	8
Volcanic sandy clay		77	122	45
Fractured volcanic rock		122	165	43
Hard volcanic rock		165	240	75
Volcanic mix sandy clay		240	290	50
Hard rock with sandy clay		290	322	32
Hard rock with white clay		322	500	178

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 257 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
9 7/8 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 500 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>257</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3/32
 From _____ feet to _____ feet
 From 100 feet to 240 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
50 Depth of Seal _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 257 feet

9. WATER LEVEL
 Static water level 21 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 85 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sargent Irrigation Company
 Contractor
 Address 9955 North Virginia Street
 Contractor
Reno, Nevada 89506
 Nevada contractor's license number issued by the State Contractor's Board 0021246
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1593
 Signed Dan Prange
 By driller performing actual drilling on site or contractor
 Date September 30, 1994

Date started September 19, 1994
 Date completed September 24, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50</u>	<u>59</u>	<u>4</u>

94 OCT 19 P 2:21
 STATE ENGINEERS OF NV