WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46296
Permit No.
Basin 101 976

NOTICE OF INTENT NO. 25794

1. OWNER Rodney Dyer
MAILING ADDRESS 1001 California Road
Hazen, NV 89408

ADDRESS AT WELL LOCATION
1001 California Road
Hazen, NV 89408

2. LOCATION NW ¼ SE ¼ Sec. 28 T. 20 N/~~S~~ R. 26 E. Churchill County
PERMIT NO. Issued by Water Resources | 010-261-09 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top SOil		0	3	3
Brown Clay		3	10	7
Brown Sand		10	23	13
Gravel Sand		23	40	17
Gravel		40	55	15
Gray Clay		55	100	45
Greenish Gray CLay		100	120	20
Coarse Black Sand		120	130	10
Green CLay & Sand		130	195	65
Gray Clay,Green & Black Sand		195	260	65
Grayish Black Clay		260	300	40
Brown & Gray Sand	X	300	315	15

Date started 8-25, 19 94
Date completed 8-25, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 315 Feet Depth Cased 315 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	50 Feet	
8 3/4 Inches	50 Feet	315 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	315

Perforations:
Type perforation Mill Cut
Size perforation 1/8
From 295 feet to 315 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 315 feet

9. WATER LEVEL
Static water level 10'6" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, INc (Contractor)
Address P.O.Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons (By driller performing actual drilling on site or contractor)
Date 11-22-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46296
Permit No.
Basin 101

NOTICE OF INTENT NO. 25794

1. OWNER Rodney Dyer
MAILING ADDRESS 1001 California Road
Hazen, NV 89408

ADDRESS AT WELL LOCATION 1001 California Road
Hazen, NV 89408

2. LOCATION NW ¼ SE ¼ Sec. 28 T 20 N/S X R 26 E CHurchill County

PERMIT NO. (Issued by Water Resources) | 010-261-09 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[XX] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [XXX] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top SOil		0	3	3
Brown Clay		3	10	7
Brown Sand		10	23	13
Gravel & Sand		23	40	17
Gravel		40	55	15
Gray CLay		55	100	45
GReenish Gray CLay		100	120	20
Coarse Black Sand		120	130	10
Green CLay & Sand		130	195	65
Gray Clay w/Green &		195		
Black Sand			260	65
Grayish Black Sand		260	300	40
Brown & Grey Sand	X	300	315	15

'94 SEP 30 PM 2:59
STATE ENGINEER

Date started 8-25, 19 94
Date completed 8-27, 19 94

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 315 Feet Depth Cased 315 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 3/4	Inches	50	Feet	315	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	315

Perforations:
Type perforation Mill Cut
Size perforation 1/8
From 295 feet to 315 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [XX] Yes [ ] No
Depth of Seal 50
Placement Method: [XX] Pumped [ ] Poured

Seal Type: [XX] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [XX] Yes [ ] No
From 50 feet to 315 feet

9. WATER LEVEL
Static water level 10' 5" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, INc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 9-1-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627