

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25819

1. OWNER D E W INC ADDRESS AT WELL LOCATION MCKINLEY AVE
 MAILING ADDRESS P.O. Box 3111 1 lot south of Eight St West
ELKO NV 89501 side
 2. LOCATION SE 1/4 NE 1/4 NW 1/4 Sec 36 T 36 N 15 R 56 E ELKO County
 PERMIT NO. 06-33H-AU-9 Ryndon Subdivision Name
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM SANDSTONE		0	3	3
CLAY		3	143	140
CLAY		143	158	15
LOOSE SANDSTONE	X	158	180	22

94 OCT -7 AM 10:4
 STATE ENGINEER'S SIGNATURE

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet
0 Inches Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.92</u>	<u>1.88</u>	<u>+2</u>	<u>150</u>

Perforations:
 Type perforation slots
 Size perforation 3/16 x 3"
 From 150 feet to 150 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 52 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 52 feet to 150 feet

9. WATER LEVEL
 Static water level 115 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started 9-14, 1994
 Date completed 9-15, 1994

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>35+</u>	<u>NV</u>	<u>4.5</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fertig Drilling Co Contractor
 Address PO Box 525 Contractor
ELKO NV 89501
 Nevada contractor's license number issued by the State Contractor's Board 31904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
 Signed Shane Fertig
 By driller performing actual drilling on site or contractor
 Date 9-15-94