56343

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46324
Permit No. 56343
Basin 02-028

NOTICE OF INTENT NO. [illegible]

1. OWNER John Delonge
MAILING ADDRESS SR 395
Winnemucca, NV. 89445

ADDRESS AT WELL LOCATION [illegible] South
SR 140 on Jackson Creek Road

2. LOCATION NE ¼ SE ¼ Sec. 28 T. 39 N/S R. 30 E. [illegible] County
PERMIT NO. New Designated Basin (Issued by Water Resources) Parcel No. McGill Canyon Rd (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other.....

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Silt		0	10	
Clay		10	70	
Sandy Gravel		70	110	

Date started 6-8, 1991
Date completed 6-9, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	10 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12	[illegible]	[illegible]	110

Perforations:
Type perforation [illegible]
Size perforation [illegible]
From 80 feet to 110 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 110 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow NO G.P.M. 100 P.S.I.
Water temperature 60 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson
Contractor
Address 10760 Valley Rd
Contractor
Winnemucca NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 375
Signed [signature]
By driller performing actual drilling on site or contractor
Date 6-11-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627