

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13195

1. OWNER LVVWD ADDRESS AT WELL LOCATION N/E CORNER CHEYENNE AVE & FOOT APACHE RD L.V.
 MAILING ADDRESS 1001 VALLEY VIEW LAS VEGAS NEVADA
 2. LOCATION NE 1/4 SW 1/4 Sec 8 T 20 N/S R. 60 E CLARK County
 PERMIT NO. 59824-T Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand, coarse to fine, silty clay		100	150	
gravel, sand, coarse to fine and silty clay		150	180	
gravel, sand, coarse to fine fine gravel, coarse to fine with sand and silt		180	190	
fine grav. coarse/fine sand		190	200	
fine grav. coarse/fine sand & silt		200	250	
gravelly sand, coarse to fine, silty clay		250	330	
well graded gravel, coarse to fine sand		330	490	
rock, gravel and sand		490	740	
rock and sand		740	1190	
red sand		1190	1220	
red rock, sand and gravel		1220	1230	
		1230	1260	

8. WELL CONSTRUCTION
 Depth Drilled 1290 Feet Depth Cased 1260 Feet
 HOLE DIAMETER (BIT SIZE)
 From 34 Inches 100 Feet To 1290 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>24</u>	<u>97</u>	<u>3/15</u>	<u>+2</u>	<u>1260</u>

Perforations:
 Type perforation CLWW
 Size perforation .100"
 From 620 feet to 660 feet
 From 700 feet to 780 feet
 From 820 feet to 1220 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement Cement Grout
 Concrete Grout
 Depth of Seal 100'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to 1290 feet

9. WATER LEVEL
 Static water level 497' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BEYLK DRILLING Contractor
 Address 555 S. HARBOR BLVD LA HABRA, CA
 Nevada contractor's license number issued by the State Contractor's Board 0007055A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1660
 Signed T. Caldwell for BDI
 By driller performing actual drilling on site or contractor
 Date 8/24/94

Date started 6/10/94, 19____
 Date completed 8/18/94, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>2843</u>	<u>548</u>	<u>47hrs</u>

'94 SEP -2 AM 132
 STATE ENGINEERING
 DIV. OF Water Resources
 Branch Office - Las Vegas, NV
 SEP 06 1994
 RECEIVED

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL-DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 46328
Permit No. _____
Basin _____

PRINT OR TYPE ONLY

Please complete this form in its entirety in

accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13105

1. OWNER Las Vegas Valley Water District ADDRESS AT WELL LOCATION NE Corner of
 MAILING ADDRESS 1001 Valley View Cheyenne Ave. and Fort Apache Rd.
Las Vegas, Nevada 98153 Las Vegas, Nevada

2. LOCATION NE 1/4 SW 1/4 Sec 8 T 20 N/S R 60 E Clark County

PERMIT NO. 59824T

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand, coarse to fine, silty clay		100	150	
Gravel, sand, coarse to fine, and silty clay		150	180	
Gravel, sand, coarse to fine, fine gravel, coarse to fine, with sand and silt		180	190	
Fine gravel, coarse/fine sand		190	200	
Fine grav./coarse/fine sand and silt		200	250	
Gravelly sand, coarse to fine, silt clay		250	330	
Well graded gravel, coarse to fine sand		330	490	
Rock, gravel and sand		490	740	
Rock, and sand		740	1190	
Red sand		1190	1220	
Red rock, sand & gravel		1220	1230	
		1230	1260	

8. WELL CONSTRUCTION
 Depth Drilled 1290 Feet Depth Cased 1260 Feet

HOLE DIAMETER (BIT SIZE)
 From 34 Inches To 100 Feet 1290 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24	97	.375	+2	1260

Perforations: Stainless Steel Type 304
 Type perforation wire wrap
 Size perforation .100"
 From 620 feet to 660 feet
 From 700 feet to 780 feet
 From 820 feet to 1220 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 100 ft. Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 0 feet to 1290 feet

9. WATER LEVEL
 Static water level 497 ft. _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BEYLIK DRILLING, INC.
 Address 555 S. Harbor Blvd.
La Habra, Calif. 90631
 Nevada contractor's license number issued by the State Contractor's Board 0007055A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1660
 Signed T. Caldwell for BEYLIK DRILLING
 By driller performing actual drilling on site or contractor
 Date Aug. 24, 1994 (Revised 2/2/95) Well NO. 95

Date started June 6, 1994, 19____
 Date completed Aug. 18, 1994, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

Static Water Level	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>497 ft.</u>	<u>2843</u>	<u>54.8</u>	<u>47 hours</u>