WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46332
Permit No.
Basin 102 8-102

NOTICE OF INTENT NO. 25991

1. OWNER Bill Faye
MAILING ADDRESS Box 728
Silver Springs, NV. 89429

ADDRESS AT WELL LOCATION Ramsey 2 Lot 74
Silver Springs, NV. 89429

2. LOCATION SW ¼ SW ¼ Sec. 23 T. 18 N/S R. 24 E. Lyon County

PERMIT NO. N/A (Issued by Water Resources) | 18-064-16 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravels And Boulders		0	86	86
Tan Clay		86	162	76
Gravels with Some Boulders	✓	162	180	18
Brownish Clay with Some Tan Clay Stricks		180	242	62
Tan Clay		242	285	43
Gravels	✓	285	320	35

Date started 7-11, 1994
Date completed 7-25, 1994

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed for about 3 Hours And produced about 40 Gallons A min			

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 310 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	60 Feet
7 7/8 Inches	60 Feet	320 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3.16	+1	310

Perforations:
Type perforation Touch Cut Hik Perf
Size perforation 1/4 x 6 Long x 5 Rows
From 180 feet to 200 feet
From 240 feet to 310 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured

Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 310 feet

9. WATER LEVEL
Static water level 127 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address PO Box 599 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7-16-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627