WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46337
Permit No. 58729
Basin 089

NOTICE OF INTENT NO. 26815

1. OWNER Ron Kitchen
MAILING ADDRESS Box 674 Carson City NV. 89702
ADDRESS AT WELL LOCATION 5350 Frank Tawn Rd Carson City NV 89702

2. LOCATION SW ¼ SW ¼ Sec 10 T 16 N/S R 19 E Washoe County
PERMIT NO. 58729 Issued by Water Resources
55-060-15 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	2	2
Hard Pack Sandstone		2	43	41
Course DG Sands		43	110	67
Hard Zone Granite		110	164	54
Broken DG		164	187	23
Hard Granite		187	250	63
Course Hard Granite		250	263	13
Broken Granite W/ Fracture S		263	300	37

'94 AUG 29 P4:01 STATE ENGINEER'S OFFICE

Date started 8-8, 19 94
Date completed 8-11, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	65	4 HRS

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 1/4 Inches	0 Feet	100 Feet
9 7/8 Inches	100 Feet	300 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	300

Perforations:
Type perforation Mill Slot
Size perforation 3x3/32
From 260 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 300 feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Company Contractor
Address 5551 Hwy 50 E #3 Contractor
Carson City NV. 89702
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack
By driller performing actual drilling on site or contractor
Date 8-12-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627