WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46346
Permit No.
Basin 104

NOTICE OF INTENT NO. 26499

1. OWNER Bruce Homer
MAILING ADDRESS 2343 Thurman Lane
Fallon, NV 89406

ADDRESS AT WELL LOCATION 5300 Riversedge Drive
Fallon, NV 89406

2. LOCATION NW ¼ NW ¼ Sec. 29 T. 19 N/S R. 28 E. CHurchill County

PERMIT NO. (Issued by Water Resources) | 008-492-25 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	15	15
Brown Clay		15	35	20
Gray Sand		35	68	33
Brown Clay		68	73	5
Brown Sand		73	85	12
Gray Clay		85	124	39
Gray Sand		124	135	11
Brownish Gray Clay		135	153	18
Brown Sand	X	153	168	15
Brown Clay		168	169	1

'94 SEP 30 PM 2:59
STATE ENGINEER

Date started 7-14, 19 94
Date completed 7-14, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 169 Feet Depth Cased 169 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	169 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	164

Perforations:
Type perforation Well Screen
Size perforation .035
From 164 feet to 169 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 169 feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons (By driller performing actual drilling on site or contractor)
Date 7-25-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627