WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46051
Permit No.
Basin 101

NOTICE OF INTENT NO. 25781

1. OWNER Billie Warner
MAILING ADDRESS 3444 Indian Lakes Road
Fallon, NV 89406

ADDRESS AT WELL LOCATION 3444 Indian Lakes Road
Fallon, NV 89406

2. LOCATION NW ¼ SW ¼ Sec. 8 T. 19 N/S R. 29 E. Churchill County

PERMIT NO. (Issued by Water Resources) | Parcel No. 007-372-04 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	3
Brown Sand		3	20	17
Brown Clay		20	22	2
Green Sand		22	50	28
Gray Clay		50	55	5
Gray Clay		55	60	5
Gray Sand		60	85	25
Brown Clay		85	97	2
Fine Brown Sand	X	87	134	47
Green Clay		134	135	1

Date started August 17, 1994
Date completed August 17, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	135 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	135

Perforations:
Type perforation Mill Cut
Size perforation 1/8
From 130 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 135 feet

9. WATER LEVEL
Static water level 5'9" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, INc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons (By driller performing actual drilling on site or contractor)
Date 9-1-94

SEP 30 P1:00 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627