

OFFICE USE ONLY
 Log No. 46354
 Permit No. _____
 Basin. 101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25791

1. OWNER Michael Hudgens ADDRESS AT WELL LOCATION _____
1320 Yucca Lane
 MAILING ADDRESS P.O. Box 150595 _____
East Ely, NV 89301 _____
Fallon, NV 89406
 2. LOCATION NW 1/4 SW 1/4 Sec 8 T. 19 N. 29 E Churchill County _____
 PERMIT NO. 010-522-02 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------|--------------|------|-----|------------|
| Fine Sand | | 0 | 10 | 10 |
| Coarse Sand | | 10 | 15 | 5 |
| Brown Clay | | 15 | 22 | 7 |
| Gray Sand | | 22 | 50 | 28 |
| Black Silt | | 50 | 60 | 10 |
| Gray Clay | | 60 | 66 | 6 |
| Gray Sand | | 66 | 79 | 13 |
| Brown Clay | | 79 | 83 | 4 |
| Fine Brown Sand | X | 83 | 120 | 37 |

'94 SEP 30 11:58
 STATE ENGINEERING

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From | To | Feet |
|-----------|----------|------------|-------------|
| <u>10</u> | <u>0</u> | <u>120</u> | <u>Feet</u> |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u> | <u>12.92</u> | <u>.188</u> | <u>0</u> | <u>115</u> |

Perforations:
 Type perforation well screen
 Size perforation .035
 From 115 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 120 feet

9. WATER LEVEL
 Static water level 5' 10" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

Date started 8-30 19 94
 Date completed 8-30 19 94

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor
 Address P.O. box 1265 Contractor
Fallon, NV 89407-1265

Nevada contractor's license number 29064
 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed William Parsons
 By driller performing actual drilling on site or contractor

Date 9-29-94