

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 27101

1. OWNER Julio Saroni ADDRESS AT WELL LOCATION Saroni Road Smith Plw  
 MAILING ADDRESS 84 Saroni Road Smith Plw 89430  
 2. LOCATION SE 1/4 NE 1/4 Sec 5 T 10 N/S R 24 E Lyon County  
 PERMIT NO. none Issued by Water Resources 10-731-02 Parcel No. none Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>sandy loam top soil</u>		<u>0</u>	<u>11</u>	<u>11</u>
<u>sand + gravel</u>		<u>11</u>	<u>25</u>	<u>14</u>
<u>brown sandy clay</u>		<u>25</u>	<u>83</u>	<u>58</u>
<u>gravel</u>		<u>83</u>	<u>95</u>	<u>12</u>
<u>brown sandy clay</u>		<u>95</u>	<u>118</u>	<u>23</u>
<u>sand + gravel</u>	<u>yes</u>	<u>118</u>	<u>145</u>	<u>27</u>
<u>brown sandy clay</u>		<u>145</u>	<u>170</u>	<u>25</u>
<u>coarse sand + gravel</u>	<u>yes</u>	<u>170</u>	<u>173</u>	<u>3</u>
<u>brown clay</u>		<u>173</u>	<u>232</u>	<u>59</u>
<u>sand + gravel</u>	<u>yes</u>	<u>232</u>	<u>245</u>	<u>13</u>
<u>brown clay</u>		<u>245</u>	<u>250</u>	<u>5</u>

8. WELL CONSTRUCTION  
 Depth Drilled 250 Feet Depth Cased 245 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches 8 Feet 50 Feet  
 To 6 Inches 50 Feet 250 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>188</u>		

Perforations:  
 Type perforation factory saw slott  
 Size perforation  
 From 2.25 feet to 2.45 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 110 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

Date started July 22 1994  
 Date completed July 25 1994

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>25+</u>	<u>0</u>	<u>3</u>	
<u>94</u>	<u>STATIC</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Edmund Miller Contractor  
 Address Box 92 Smith Plw 89430 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 32166  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718  
 Signed Edmund Miller  
 By driller performing actual drilling on site or contractor  
 Date July 29 1994