WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46570
Permit No.
Basin 076

NOTICE OF INTENT NO. 257942

1. OWNER Dave Stix
MAILING ADDRESS 4830 Farm Dist Rd. Fernley NV
ADDRESS AT WELL LOCATION 4830 Farm Dist Rd. Farm district Rd

2. LOCATION SW ¼ SE ¼ Sec. 24 T. 20 N/S R. 25 E Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 21-30/-12 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil, Boulder, Clay		0	8	8
Sand		8	16	8
Sand Gravel		16	23	7
Gravel, Clay		23	85	62
Clay		85	101	16
Cemented Gravel		101	107	6
Clay (Blue Clay)		107	135	28
Clay (Blue-Green)		135	145	10
Cemented Gravel		145	157	12
Clay W/ Gravel Streaks		157	180	23
Clay (Green)		180	205	25
Clay (Blue Clay)		205	223	18
Gravel		223	254	31
Shale, Quartz (Quartzite Fragment)		254	259	5

RECEIVED SEP 15 P 3:53 ENGINEERS OFFICE

Date started 8/10/94, 19
Date completed 8/18/94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
165-170		2½
1½	(120')	1½

8. WELL CONSTRUCTION
Depth Drilled 259 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	1	259

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.	1.88	+1	259

Perforations:
Type perforation Torch Cut
Size perforation 3/16 x 4" x 6 rows per
From 145 feet to 155 feet
From 219 feet to 259 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 259 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 61 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling (Contractor)
Address PO. 599 (Contractor)
S.S. NV, 89429
Nevada contractor's license number issued by the State Contractor's Board 0031341
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed Janice Leach (By driller performing actual drilling on site or contractor)
Date 8/18/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627