

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34839

1. OWNER Morris D Myers ADDRESS AT WELL LOCATION 857 Sandy St  
 MAILING ADDRESS 857 Sandy St, Lopez Lake Gardnerville Nev, 89410  
 2. LOCATION SE 1/4 N 1/4 Sec 10 T 10 N/S R 22 E Douglas County  
 PERMIT NO. 39-080-05 Issued by Water Resources Parcel No. none Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>0 to 35 small Rock + yellow clay</u>		<u>0</u>	<u>35</u>	<u>35</u>
<u>Gray gravel</u>	<u>V</u>	<u>35</u>	<u>55</u>	<u>20</u>
<u>hard pan + rock</u>		<u>55</u>	<u>62</u>	<u>7</u>
<u>small rock with some clay seams</u>		<u>62</u>	<u>100</u>	<u>38</u>

8. WELL CONSTRUCTION

Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10</u> Inches	<u>0</u> Feet	<u>60</u> Feet
<u>6</u> Inches	<u>60</u> Feet	<u>100</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>1 9/8</u>	<u>0</u>	<u>100</u>

Perforations:  
 Type perforation Factory saw slot  
 Size perforation \_\_\_\_\_  
 From 60 feet to 100 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 60  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 30 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

Date started July 5, 1994  
 Date completed July 10, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>5</u>	<u>70</u>	<u>2 hrs</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Edmund Miller Contractor  
 Address Box 92 Smith Nev. Contractor  
 Nevada contractor's license number 32166 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718  
 Signed Edmund Miller By driller performing actual drilling on site or contractor  
 Date July 29 1994