

OFFICE USE ONLY
 Log No. 46377
 Permit No. _____
 Basin 085

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27295

1. OWNER KATHY HUTCHISON ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 5738 Flinn Drive 900 Sky Ranch Road
Sparks, Nevada 89433 Sparks, Nevada 89436
 2. LOCATION NE 1/4 SE 1/4 Sec. 6 T 21N N/S R 21 E Washoe County
 PERMIT NO. 076-190-23 Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sand		0	7	7
Granite sands			7	9
Decomposed granite, w/brown clay mixed		7	61	54
Weathered granite		61	180	119
Soft zone (NO WATER)		180	183	3
White granite		183	290	107
Weathered granite		290	338	48
White granite		338	442	4
Soft weathered granite		442	463	21
White granite		463	554	91
Soft zone (NO WATER)		554	555	1
White granite		555	612	57
Soft zone (APP 2 GPM)	X	612	614	2
White granite		614	652	38
Fracture (APP 8 GPM)	X	652	653	1
White granite		653	688	35
Fracture	X	688	689	1
White granite		689	700	11

'94 SEP 26 P 3:13
 STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 700 Feet Depth Cased 700 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
2 10" Inches 0 Feet 53 Feet
8 5/8 Inches 53 Feet 700 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	700

 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 600 feet to 620 feet
 From 640 feet to 660 feet
 From 680 feet to 700 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 53 feet
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 53 feet to 700 feet

9. WATER LEVEL
 Static water level 499 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 Date September 20, 1994

Date started 9-7-94, 19____
 Date completed 9-15-94, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		