

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25283

1. OWNER Florida Canyon Mine, Inc ADDRESS AT WELL LOCATION Florida Canyon Mine
 MAILING ADDRESS Post Office Box 330 Humboldt exit and Interstate 80
Imlay, Nevada 89418

2. LOCATION SW 1/4 NW 1/4 Sec 3 T 31 S R 33 E Pershing County
 PERMIT NO. 48999 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Broken rock & brown clay		0	106	106
Broken rock with 80% clay		106	300	194
Gravel with 60% clay		300	450	150
Red rock & red clay 50%		450	662	212
Hard gray siltstone		662	750	88
Gray clay		750	780	30

8. WELL CONSTRUCTION
 Depth Drilled 780 Feet Depth Cased 780 Feet

HOLE DIAMETER (BIT SIZE)
 From To
14 3/4 Inches 0 Feet 600 Feet
8 3/4 Inches 600 Feet 780 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	28.04	.250	+2	600
6 5/8	17.02	.250	600	780

Perforations:
 Type perforation Full Flo Louvered & Mill Slot
 Size perforation .080 & 3/32
 From 400 feet to 780 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 55 feet to 600 feet

Date started July 27, 1994
 Date completed August 14, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>500</u>		<u>6</u>

9. WATER LEVEL
 Static water level UNKNOWN - NOT MEASURED DUE TO H2O TEMP feet below land surface
 Artesian flow _____ G.P.M. P.S.I. POOR quality
 Water temperature 190+ °F Quality POOR

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sargent Irrigation Company Contractor
 Address 9955 North Virginia Street Contractor
Reno, Nevada 89506

Nevada contractor's license number issued by the State Contractor's Board 0021246
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1593

Signed San Sargent
 By driller performing actual drilling on site or contractor
 Date August 24, 1994