WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46391
Permit No.
Basin 084

NOTICE OF INTENT NO. 17741

1. OWNER Rockwell International Rocketdyne Div.
MAILING ADDRESS 6633 Canoga Ave.
Canoga Park, CA 91303
ADDRESS AT WELL LOCATION former Rockwell Nevada field Lab in Palamino Valley Nevada 26400 Whiskey Gulch Rd.

2. LOCATION SE ¼ NE ¼ Sec. 07 T. 22N N/S R. 22E E. Washoe County
PERMIT NO. WaiverM/O-431-B (Issued by Water Resources) | 77-320-05 (Parcel No.) | ~~n/a~~ Palamino J Unit II 26 2 2 3 (Subdivision Name)

3. AS-1 WORK PERFORMED Area D
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravelly sand		0	18	fine
Gravelly sand		18	35	fine
Clayey Sand		35	38	med
Clayey Silt/Silty Clay		38	47	moist
Gravelly Sand		47	56	course
Clayey Sand		56	76	gravel
Sandy Gravel		76	91	courser
Tuff		91	92	moist

Date started 5/23, 19 94
Date completed 5/25, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
n/a			

8. WELL CONSTRUCTION
Depth Drilled 91.5 Feet Depth Cased 91.5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8.75 Inches	0 Feet	91.5 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2-3/8	sch40	n/a	0	91.5

Perforations:
Type perforation factory sawed
Size perforation .020
From 86.0 feet to 90.6 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 74'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No 10' bentonite barrier
From 84.0 feet to 91.5 feet

9. WATER LEVEL
Static water level 46.3 feet below land surface
Artesian flow n/a G.P.M. n/a P.S.I.
Water temperature n/a °F Quality n/a

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hedman Drilling Co. (Contractor)
Address P.O. Box 726 (Contractor)
Lincoln, CA 95648
Nevada contractor's license number issued by the State Contractor's Board 0033492
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1555
Signed Steve Hedman (By driller performing actual drilling on site or contractor)
Date 5/25/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627