WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46398
Permit No.
Basin 084

NOTICE OF INTENT NO. 17741

1. OWNER Rockwell International-Rocketdyne DIV
MAILING ADDRESS 6633 Canoga Ave.
Canoga Park, CA 91303

ADDRESS AT WELL LOCATION former Rockwell
Nevada field lab in Palamino Valley
Nevada 2640 Whiskey Springs Rd

2. LOCATION SE ¼ NE ¼ Sec. 07 T. 22N N/S R. 22E E. Washoe County
PERMIT NO. WaiverM/O-431-B (Issued by Water Resources) 77-320-08 (Parcel No.) n/a Palamino U. Unit II 7 & 23 (Subdivision Name)

3. PS-2/V-2 WORK PERFORMED Area D
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravelly Sand		0	9	fine
Gravelly Sand		9	27	f-course
Gravelly Sand		27	37	med
Clayey Sand		37	42	gravel
Clayey Silt		42	47	fine
Gravelly Sand		47	55	f-course
Glayey Sand		55	67	gravel

Date started 6/4, 1994
Date completed 6/4, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
n/a			

8. WELL CONSTRUCTION
Depth Drilled 67. Feet Depth Cased 67 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8.75 Inches		0 Feet	67 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2-3/8	sch40	n/a	0	55.5PS-2
1-5/16	sch80	n/a	2.3	43.0V-2

Perforations:
Type perforation factory sawed
Size perforation .020
From 38.4 feet to 42.7 feet V-2
From 50.4 feet to 54.6 feet PS-2
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 34'
Placement Method: ☒ Pumped ☐ Poured
with V-2 2' and PS-2 4'
Gravel Packed: ☒ Yes ☐ No
From V-2 36' PS-2 48' feet to V-2 43' 67' feet

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout
bentonite barrier

9. WATER LEVEL
Static water level 47.9 feet below land surface
Artesian flow n/a G.P.M. n/a P.S.I.
Water temperature n/a °F Quality n/a

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hedman Drilling Co. (Contractor)
Address P.O. Box 726 (Contractor)
Lincoln, CA 95648
Nevada contractor's license number issued by the State Contractor's Board 0033492
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1555
Signed Steve Hedman (By driller performing actual drilling on site or contractor)
Date 6/4/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627